



REQUEST FOR QUOTATION

Date : May 3, 2017
Quotation No. : 0345-04-2017

Company Name : _____
Address : _____

Please quote your lowest price on the item/s listed below, subject to the General Conditions stating the shortest time of delivery and submit your quotation duly signed by you or your representative on or before 5:00 PM of May 10, 2017 in a sealed envelope.


MS. SHEENA E. BULAY
Customer Service Assistant B.

General Conditions:


- All entries must be printed/typed written.
- Delivery period within THREE (3) Calendar Days upon receipt of the Purchase Order.
- Warranty shall be for a period of six (6) months for supplies and materials and one (1) year for equipment from date of acceptance by the procuring entity,
- Prices quoted shall be FOB La Trinidad and in Philippine Pesos
- Price validity shall be for a period of Thirty (30) Calendar Days.
- The following shall be attached upon submission of the Request for Quotation:
 - PhilGEPS registration
 - Valid Mayor's Permit
 - Statement that it is not blacklisted or barred from bidding by the Gov't or any of its agency, office, corporation or LGU.
 - Sworn statement that it is not related to the Head of Procuring Entity by consanguinity or affinity up to the third civil degree.
 - Original brochures showing specifications of the products being offered. (if required)
- For Lot Award
All items to be grouped together to form one (1) complete Lot that will be awarded to one Bidder to form one (1) complete contract. Bidder must offer/quote on all items, otherwise, bidder shall be automatically be disqualified.
- Award of contract shall be made to the lowest quotation which complies with the minimum technical specifications and other terms and conditions stated therein.
- Any interlineations, erasures or overwriting shall be valid only if they are signed or initialed by the bidder or his/her duly authorized representative/s.
- Liquidated damages equivalent to one tenth of one percent (0.001 %) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day of delay. The LTWD shall rescind the contract once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract. without prejudice to other courses of action and remedies open to it.
- The LTWD reserves the right to accept or reject any or all quotations and to impose additional terms and conditions as it may deem proper.

Item No.	Item and Description	Compliance to Specifications	Quantity	Unit	Unit Price	Lot Price
1 LOT SUPPLY AND DELIVERY OF PUMPS & VARIOUS MATERIALS						
BILL OF QUANTITIES						
A	38 mm ² THW Electric Wire, stranded ,600 V		(Two Hundred Twenty Five) 225	Meters		



Date : May 3, 2017
Quotation No. : 0345-04-2017

Item No.	Item and Description	Compliance to Specifications	Quantity	Unit	Unit Price	Lot Price												
B	Submersible Pump		(Two) 2	Units														
	Specifications:																	
	a. All stainless construction, except for the following:																	
	<table><tr><td>Components</td><td>Material</td></tr><tr><td>O ring</td><td>NBR</td></tr><tr><td>Lower Bearing</td><td>Stainless Steel/NBR</td></tr><tr><td>Neck Ring</td><td>NBR/PPS</td></tr><tr><td>Spacing Washer for Stop Ring</td><td>Carbon/graphite HY 22</td></tr><tr><td>Intermediate Bearing</td><td>NBR</td></tr></table>	Components	Material	O ring	NBR	Lower Bearing	Stainless Steel/NBR	Neck Ring	NBR/PPS	Spacing Washer for Stop Ring	Carbon/graphite HY 22	Intermediate Bearing	NBR					
Components	Material																	
O ring	NBR																	
Lower Bearing	Stainless Steel/NBR																	
Neck Ring	NBR/PPS																	
Spacing Washer for Stop Ring	Carbon/graphite HY 22																	
Intermediate Bearing	NBR																	
	b. Q= 17 cubic meters per hour																	
	c. TDH = 80 m																	
	d. Number of bowls = 6																	
	e. Length of pump = 616 mm																	
	f. Diameter of discharge bore = 3 inches																	
	g. Solid Suction Interconnector																	
	h. with cable guard																	
	i. with non return valve																	
C	Submersible Pump		(One) 1	Unit														
	Specifications:																	
	a. All stainless construction, except for the following:																	
	<table><tr><td>Components</td><td>Material</td></tr><tr><td>O ring</td><td>NBR</td></tr><tr><td>Lower Bearing</td><td>Stainless Steel/NBR</td></tr><tr><td>Neck Ring</td><td>NBR/PPS</td></tr><tr><td>Spacing Washer for Stop Ring</td><td>Carbon/graphite HY 22</td></tr><tr><td>Intermediate Bearing</td><td>NBR</td></tr></table>	Components	Material	O ring	NBR	Lower Bearing	Stainless Steel/NBR	Neck Ring	NBR/PPS	Spacing Washer for Stop Ring	Carbon/graphite HY 22	Intermediate Bearing	NBR					
Components	Material																	
O ring	NBR																	
Lower Bearing	Stainless Steel/NBR																	
Neck Ring	NBR/PPS																	
Spacing Washer for Stop Ring	Carbon/graphite HY 22																	
Intermediate Bearing	NBR																	
	a. Q= 30 cubic meters per hour																	
	b. TDH = 50 m																	
	c. Number of bowls= 4																	
	d. Length of pump= 653 mm																	
	e. Diameter of discharge bore = 3 inches																	
	f. Solid suction interconnector																	
	g. with cable guard																	
	i. with non return valve																	
D	4 inch diameter Flexible Rubber Connector		(Two) 2	pcs														
	ANSI 150 ASTM A 536 65-45-12																	
E	High Pressure Control Switch		(Ten) 10	pcs														
	Range : 6 to 32 bars																	
	Differential : 3 bars																	
	Connection : ¼ inch flare																	
	Switch : SPDT																	



Republic of the Philippines
LA TRINIDAD WATER DISTRICT
FA 249-B Km. 4, Balili, La Trinidad
Benguet Province 2601
Tel. Nos.: (074)-422-2679 / (074)-422-2078
Telefax No.: (074)-422-1848

Date : May 3, 2017
Quotation No. : 0345-04-2017

Item No.	Item and Description	Compliance to Specifications	Quantity	Unit	Unit Price	Lot Price
F	Pressure Guage		(Fifty) 50	pcs		
	Range : 0 to 300 psi					
	Dial : 4 ½ inches					
	Case : Black Aluminum					
	Lens : Glass					
	Ring : Stainless Steel Ring					
	Pointer " Aluminum Micrometer					
	Wetted Parts : Brass or 316 Stainless Steel					
	Connection : ¼ NPT					
	Accuracy :0.5 % ANSI/ASME Grade 2 A					
	Application: For fresh water					
G	10" Dia x 8ft Stainless Steel Barrel		(One) 1	unit		
TOTAL LOT PRICE:						
NOTE:						
1. Approved Budget for the Contract: <u>PhP 614,100.19</u>						
2. Request for Quotation may be downloaded & sent through postal or courier services to: Ms. Sheena E. Bulay						
Customer Service Assistant B, La Trinidad Water District, F.A.249-B, Balili, La Trinidad, Benguet						

Delivery period : _____
Warranty : _____
Price validity : _____

After having carefully read and accepted your General Conditions, I/We quote you on the item/s
Signature _____
Printed Name _____
Tel./Mobile phone No. _____
Facsimile No. _____
E-mail address _____
Date _____

at prices quoted above.