

Republic of the Philippines

DEPARTMENT OF SCIENCE AND TECHNOLOGY

Cordillera Administrative Region Regional Standards and Testing Laboratory



WTL-020-14-CAR-G



DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0220; MIC-0222

Date Submitted

: February 12, 2018

Date Analyzed Date Reported : February 12-14, 2018 : February 15, 2018

Submitted by

: Customer Name

Address

Name of Company : LA TRINIDAD WATER DISTRICT : Km. 4, Balili, La Trinidad, Benguet

age	: Page 1 of 2		allii, La Trinidad, Benguet	
SAMPLE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2017)
MIC-0368 to MIC- 0383 and MIC 0387	17 Domestic water samples from terminal points placed in sterilized reagent bottle and with written label, 2 _T , 3 _T , 4 _T , 5 _T , 6 _T , 9 _T , 12 _T , 14 _T , Lubas _T , JICA _{T2} PPSS _{T1} , SWAMP _T , A _T , PICOWELL _{T1} and PICOWELL _{T2} , 8 _T	Total Coliform Count	2T - <1.1 MPN/100 mL 3T - <1.1 MPN/100 mL 4T - <1.1 MPN/100 mL 5T - <1.1 MPN/100 mL 6T - <1.1 MPN/100 mL 9T - <1.1 MPN/100 mL 12T - <1.1 MPN/100 mL 14T - <1.1 MPN/100 mL Lubast - <1.1 MPN/100 mL JICAT1 - <1.1 MPN/100 mL JICAT2 - <1.1 MPN/100 mL PPSST1 - <1.1 MPN/100 mL SWAMPT - <1.1 MPN/100 mL PICOWELLT1 - <1.1 MPN/100 mL PICOWELLT2 - <1.1 MPN/100 mL PICOWELLT2 - <1.1 MPN/100 mL PICOWELLT3 - <1.1 MPN/100 mL	<1.1 MPN/ 100 mL
		E. coli	All samples (terminal) – <1.1 MPN/100 mL	<1.1 MPN/ 100 mL
= 1		Heterotrophic Plate Count	2T - 31 CFU/mL 3T - <1* CFU/mL 4T - <1* CFU/mL 5T - <1* CFU/mL 6T - <1* CFU/mL 9T - <1* CFU/mL 12T - <1* CFU/mL 14T - <1* CFU/mL Lubast - <1* CFU/mL JICAT1 - <1* CFU/mL JICAT2 - 27* CFU/mL PPSST1 - <1* CFU/mL SWAMPT - <1* CFU/mL PICOWELLT1 - <1* CFU/mL PICOWELLT2 - <1* CFU/mL PICOWELLT2 - <1* CFU/mL PICOWELLT3 - <1* CFU/mL PICOWELLT4 - <1* CFU/mL PICOWELLT5 - <1* CFU/mL	<500 CFU/mL

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com URL: http://car.dost.gov.ph







DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0220; MIC-0222

Date Submitted

: February 12, 2018

Date Analyzed Date Reported

: February 12-14, 2018 : February 15, 2018

Submitted by

: Customer Name

Name of Company: LA TRINIDAD WATER DISTRICT

Address

: Km. 4, Balili, La Trinidad, Benguet

Page

: Page 2 of 2

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215B; 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from all terminal points NEGATIVE for E. coli. Heterotrophic Plate Count of all water samples are within the standard limit set by the PNSDW.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory. *Estimated Heterotrophic Plate Count

Analyzed by:

Confirmed and Approved for Release by:

Approved PAB Signatory

NANCY A. BANTOG Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com



Republic of the Philippines

DEPARTMENT OF SCIENCE AND TECHNOLOGY

Cordillera Administrative Region Regional Standards and Testing Laboratory





DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0219 and MIC-0226

Date Submitted

: February 12, 2018

Date Analyzed

: February 12-14, 2018

Date Reported

: February 15, 2018

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2017)
MIC-0351 to 0367 and MIC- 0391 to MIC-0398	to 0367 samples from source points placed in	Total Coliform Count	2s - >8 MPN/100 mL 3s - <1.1 MPN/100 mL 4s - >8 MPN/100 mL 5s - <1.1 MPN/100 mL 6s - <1.1 MPN/100 mL 8s - <1.1 MPN/100 mL 9s - <1.1 MPN/100 mL 12s - <1.1 MPN/100 mL 12s - <1.1 MPN/100 mL 14s - >8 MPN/100 mL Lubass - >8 MPN/100 mL PPSSs - >8 MPN/100 mL JICAs1 - >8 MPN/100 mL JICAs2 - <1.1 MPN/100 mL Swamps - <1.1 MPN/100 mL Picos1 - >8 MPN/100 mL	<1.1 MPN/100mL
		E. coli	2s - >8 MPN/100 mL 4s - >8 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100MI As - >8 MPN/100 mL PPSSs - >8 MPN/100mL JICAs1 - >8 MPN/100mL Picos1 - 2.6 MPN/100mL	<1.1 MPN/100mL

M

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 -Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com



Republic of the Philippines DEPARTMENT OF SCIENCE AND TECHNOLOGY

Cordillera Administrative Region Regional Standards and Testing Laboratory





DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0219 and MIC-0226

Date Submitted

: February 12, 2018

Date Analyzed Date Reported : February 12-14, 2018 : February 15, 2018

Submitted by

: Customer Name

Name of Company

: LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

Page	: Page 2 of 2			
MIC-0351 to 0367 and MIC- 0391 to MIC-0398	17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2s, 3s, 4s, 5s, 6s, 8s, 9s, 12s, 14s, Lubass, As, PPSSs, JICAs1, JICAs2, SWAMPs Picos and Picos2.	Heterotrophic Plate Count	2s - 257 CFU/mL 3s - 151CFU/mL 4s - 2, 140 CFU/mL 5s - 4* CFU/mL 6s - 33 CFU/mL 8s - 50 CFU/mL 9s - <1* CFU/mL 12s - <1* CFU/mL 14s - 1,315 CFU/mL Lubass - 25* CFU/mL Lubass - 25* CFU/mL As - 200 CFU/mL PPSSs - 1, 910 CFU/mL JICAs1 - 1,510 CFU/mL JICAs2 - 3* CFU/mL Swamps - 224 CFU/mL Picos1 - 89 CFU/100mL Picos2 - <1* CFU/100mL	<500 CFU/mL
				- Kanada a a a a a a a a a a a a a a a a a

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition. Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2s, 4s, 14s, Lubass, As, PPSSS, JICAs1, and Picos1 are POSITIVE for E. coli.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory. * Estimated Heterotrophic Plate Count

Analyzed by:

Certified by:

Confirmed and Approved for Release by:

MARVI JO . BALABAG Analyst

Booker JAMIE BETH B. GALIAN Approved PAB Signatory

NANCY A. BANTOG Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com







DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0219 and MIC-0226

Date Submitted Date Analyzed

: February 12, 2018 : February 12-14, 2018 : February 15, 2018

Date Reported

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2017)
MIC-0351 to 0367 and MIC- 0391 to MIC-0398	to 0367 samples from source points placed in	Total Coliform Count	2s - >8 MPN/100 mL 3s - <1.1 MPN/100 mL 4s - >8 MPN/100 mL 5s - <1.1 MPN/100 mL 6s - <1.1 MPN/100 mL 8s - <1.1 MPN/100 mL 9s - <1.1 MPN/100 mL 12s - <1.1 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100mL Lubass - >8 MPN/100 mL PPSSs - >8 MPN/100 mL JICAs1 - >8 MPN/100mL JICAs2 - <1.1 MPN/100mL Swamps - <1.1 MPN/100mL Picos1 - >8 MPN/100mL Picos2 - <1.1 MPN/100mL	<1.1 MPN/100mL
	E. coli	2s - >8 MPN/100 mL 4s - >8 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100MI As - >8 MPN/100 mL PPSSs - >8 MPN/100mL JICAs1 - >8 MPN/100mL Picos1 - 2.6 MPN/100mL	<1.1 MPN/100mL	

M

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com







DENR RECOGNIZED C.R No. 078/2015

FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-022018-MIC-0219 and MIC-0226

Date Submitted Date Analyzed

: February 12, 2018 : February 12-14, 2018

Date Reported Submitted by

: February 15, 2018 : Customer Name

Name of Company

: LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 2 of 2

MIC-0351 to 0367 and MIC- 0391 to MIC-0398	17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2s, 3s, 4s, 5s, 6s, 8s, 9s, 12s, 14s, Lubass, As, PPSSs, JICAs1, JICAs2, SWAMPs Picos and Picos2.	Heterotrophic Plate Count	2s - 257 CFU/mL 3s - 151CFU/mL 4s - 2, 140 CFU/mL 5s - 4* CFU/mL 6s - 33 CFU/mL 8s - 50 CFU/mL 9s - <1* CFU/mL 12s - <1* CFU/mL 14s - 1,315 CFU/mL Lubass- 25* CFU/mL Lubass- 25* CFU/mL JICAs1 - 1,510 CFU/mL JICAs2 - 3* CFU/mL Swamps- 224 CFU/mL Picos1 - 89 CFU/100mL Picos2 - <1* CFU/100mL	<500 CFU/mL
--	--	------------------------------	---	-------------

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2s, 4s, 14s, Lubass, As, PPSSS, JICAs1, and Picos1 are POSITIVE for E. coli.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

* Estimated Heterotrophic Plate Count

Analyzed by:

Certified by:

Confirmed and Approved for Release by:

MARVI JOYO BALABAG Analyst JAMIE BETH B. GALIAN Approved PAB Signatory

NANCY A. BANTOG Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com