



FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0292

Date Submitted

: March 12, 2018

Date Analyzed

: March 12-14, 2018

Date Reported

: March 15, 2018

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, Balili, La Trinidad, Benguet

Page	: Page 1 of 2		allii, La Trinidad, Benguet	
SAMPLE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2017)
MIC-0525 to MIC- 0541	17 Domestic water samples from terminal points placed in sterilized reagent bottle and with written label, 2 _T , 3 _T , 4 _T , 5 _T , 6 _T , 8 _T , 9 _T , 12 _T , 14 _T , Lubas _T , JICA _{T2} PPSS _{T1} , SWAMP _T , A _T , PICOWELL _{T1} and PICOWELL _{T2} ,	Total Coliform Count	2T - <1.1 MPN/100 mL 3T - <1.1 MPN/100 mL 4T - <1.1 MPN/100 mL 5T - <1.1 MPN/100 mL 6T - <1.1 MPN/100 mL 8T - <1.1 MPN/100 mL 9T - <1.1 MPN/100 mL 12T - <1.1 MPN/100 mL 14T - <1.1 MPN/100 mL Lubast - <1.1 MPN/100 mL JICAT1 - <1.1 MPN/100 mL JICAT2 - <1.1 MPN/100 mL SWAMPT - <1.1 MPN/100 mL PPSST1 - <1.1 MPN/100 mL PICOWELLT1 - <1.1 MPN/100 mL PICOWELLT1 - <1.1 MPN/100 mL	<1.1 MPN/ 100 mL
		E. coli	All samples (terminal) – <1.1 MPN/100 mL	<1.1 MPN/ 100 mL
		Heterotrophic Plate Count	2T - <1* CFU/mL 3T - <1* CFU/mL 4T - <1* CFU/mL 5T - <1* CFU/mL 6T - <1* CFU/mL 8T - <1* CFU/mL 9T - <1* CFU/mL 12T - <1* CFU/mL 14T - 2* CFU/mL LUBAST - <1* CFU/mL JICAT1 - <1* CFU/mL JICAT2 - 138 CFU/mL PPSST1 - <1* CFU/mL SWAMPT - <1* CFU/mL PICOWELLT1 - 1* CFU/mL PICOWELLT2 - 4* CFU/mL	<500 CFU/mL

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com





FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0292

Date Submitted

: March 12, 2018

Date Analyzed

: March 12-14, 2018

Date Reported

: March 15, 2018

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, Balili, La Trinidad, Benguet

Page

: Page 2 of 2

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215B; 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from all terminal points NEGATIVE for E. coli. Heterotrophic Plate Count of all water samples are within the standard limit set by the PNSDW.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory. *Estimated Heterotrophic Plate Count

Analyzed by:

Confirmed and Approved for Release by:

JAMIE BETH B. GALIAN Approved PAB Signatory

NANCY A. BANTOG A Quality Manager

real ane

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com





FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0293 and MIC-0303

Date Submitted Date Analyzed

: March 12, 2018 : March 12-14, 2018

Date Reported

: March 15, 2018

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2007)
MIC-0544 to 0560 and MIC- 0574 to MIC-0580	17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2s, 3s, 4s, 5s, 6s, 8s, 9s, 12s, 14s, Lubass, As, PPSSs, JICAs1, JICAs2, SWAMPs Picos and Picos2.	Total Coliform Count	2s - >8 MPN/100 mL 3s - <1.1 MPN/100 mL 4s - 2.6 MPN/100 mL 5s - <1.1 MPN/100 mL 6s - <1.1 MPN/100 mL 8s - <1.1 MPN/100 mL 9s - <1.1 MPN/100 mL 12s - <1.1 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100mL Lubass - >8 MPN/100mL JICAs1 - >8 MPN/100mL JICAs2 - <1.1 MPN/100mL Swamps - <1.1 MPN/100mL Picos1 - >8 MPN/100mL Picos1 - >8 MPN/100mL	<1.1 MPN/100mL
		E. coli	2s - >8 MPN/100 mL 4s - <1.1 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100mL PPSSs - >8 MPN/100mL JICAs1 - >8 MPN/100mL Picos1 - 2.6 MPN/100mL	<1.1 MPN/100mL



Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com





FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0293 and MIC-0303

Date Submitted

: March 12, 2018

Date Analyzed

: March 12-14, 2018 : March 15, 2018

Date Reported

Submitted by

: Customer Name

Name of Company

: LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 2 of 2

aye	. raye 2 01 2		
	Heterotrophic Plate Count	9s - <1* CFU/mL 12s - 16* CFU/mL 14s - 1,000 CFU/mL Lubass- 49 CFU/mL As - 4* CFU/mL PPSSs - 14,700 CFU/mL JICAs1 - 525 CFU/mL JICAs2 - 290 CFU/mL Swamps- 1,310 CFU/mL Picos1 - 57 CFU/100mL	<500 CFU/mL
		Picos2 - 24* CFU/100mL	

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition. Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2s, 14s, Lubass, PPSSs JICAst and Picost are POSITIVE for E. coli.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

* Estimated Heterotrophic Plate Count

Analyzed by:

Certified by:

Confirmed and Approved for Release by:

MARVI JC Analyst

JAMIE BETH B. GALIAN Approved PAB Signatory

Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com





FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0293 and MIC-0303

Date Submitted

: March 12, 2018

Date Analyzed Date Reported

: March 12-14, 2018 : March 15, 2018

Submitted by

: Customer Name

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2007)
MIC-0544 to 0560 and MIC- 0574 to MIC-0580 17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2s, 3s, 4s, 5s, 6s, 8s, 9s, 12s, 14s, Lubass, As, PPSSs, JICAs1, JICAs2, SWAMPs Picos and Picos2.	Total Coliform Count	2s - >8 MPN/100 mL 3s - <1.1 MPN/100 mL 4s - 2.6 MPN/100 mL 5s - <1.1 MPN/100 mL 6s - <1.1 MPN/100 mL 8s - <1.1 MPN/100 mL 9s - <1.1 MPN/100 mL 12s - <1.1 MPN/100mL 14s - >8 MPN/100mL Lubass - >8 MPN/100mL Lubass - >8 MPN/100mL JICAs1 - >8 MPN/100mL JICAs2 - <1.1 MPN/100mL JICAs2 - <1.1 MPN/100mL Swamps - <1.1 MPN/100mL Picos1 - >8 MPN/100mL Picos1 - >8 MPN/100mL	<1.1 MPN/100mL	
	er e	E. coli	2s - >8 MPN/100 mL 4s - <1.1 MPN/100 mL 14s - >8 MPN/100mL Lubass - >8 MPN/100mL PPSSs - >8 MPN/100mL JICAs1 - >8 MPN/100mL Picos1 - 2.6 MPN/100mL	<1.1 MPN/100mL



Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com





FDA ACCREDITED FDA LA-2014-018

REPORT OF ANALYSIS

Req. Ref. No.

: CAR-032018-MIC-0293 and MIC-0303

Date Submitted

: March 12, 2018

Date Analyzed

: March 12-14, 2018

Date Reported

: March 15, 2018

Submitted by

: Customer Name

Name of Co

Name of Company : LA TRINIDAD WATER DISTRICT

Address

: Km. 4, La Trinidad, Benguet

Page

: Page 2 of 2

age	. Page 2 of 2		
	Heterotrophic Plate Count	2s - 295 CFU/mL 3s - <1* CFU/mL 4s - 14* CFU/mL 5s - 6* CFU/mL 6s - 10* CFU/mL 8s - 59 CFU/mL 9s - <1* CFU/mL 12s - 16* CFU/mL 14s - 1,000 CFU/mL Lubass - 49 CFU/mL Lubass - 49 CFU/mL PPSSs - 14,700 CFU/mL JICAs1 - 525 CFU/mL JICAs2 - 290 CFU/mL Swamps - 1,310 CFU/mL Picos1 - 57 CFU/100mL Picos2 - 24* CFU/100mL	<500 CFU/mL

METHODOLOGY:

Total Coliform Count / Escherichia coli

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition. Heterotrophic Plate Count.

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2s, 14s, Lubass, PPSSs JICAs1 and Picos1 are POSITIVE for E. coli.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

* Estimated Heterotrophic Plate Count

Analyzed by:

Certified by:

Confirmed and Approved for Release by:

MARVI JOY .. BALAB Analyst

JAMIE BETH B. GALIAN Approved PAB Signatory NANCY A. BANTOG

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601

Tel. No. (63)(074)422-0979 Fax No. (63)(074)422-2214 e-mail address: rstlcar@gmail.com