



REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0433
 Date Submitted : May 9, 2018
 Date Analyzed : May 9-11, 2018
 Date Reported : May 15, 2018
 Submitted by : Customer Name :
 Name of Company : **LA TRINIDAD WATER DISTRICT**
 Address : Km. 4, Balili, La Trinidad, Benguet

Page : Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2017)
MIC-0870 to MIC- 0885	17 Domestic water samples from terminal points placed in sterilized reagent bottle and with written label, 2 _T , 3 _T , 4 _T , 5 _T , 6 _T , 8 _T , 9 _T , 12 _T , 14 _T , Lubas _T , JICA _{T1} , JICA _{T2} , PPSS _{T1} , SWAMP _T , A _T , PICOWELL _{T1} and PICOWELL _{T2} ,	Total Coliform Count	2 _T – < 1.1 MPN/100 mL 3 _T – < 1.1 MPN/100 mL 4 _T – < 1.1 MPN/100 mL 5 _T – < 1.1 MPN/100 mL 6 _T – < 1.1 MPN/100 mL 8 _T – < 1.1 MPN/100 mL 9 _T – < 1.1 MPN/100 mL 12 _T – < 1.1 MPN/100 mL 14 _T – < 1.1 MPN/100 mL Lubas _T – < 1.1 MPN/100 mL JICA _{T1} – < 1.1 MPN/100 mL JICA _{T2} – < 1.1 MPN/100 mL PPSS _{T1} – < 1.1 MPN/100 mL SWAMP _T – < 1.1MPN/100 mL A _T – < 1.1 MPN/100 mL PICOWELL _{T1} – <1.1MPN/100mL PICOWELL _{T2} – <1.1MPN/100mL	< 1.1 MPN/ 100 mL
		<i>E. coli</i>	All samples (terminal) – <1.1 MPN/100 mL	< 1.1 MPN/ 100 mL
		Heterotrophic Plate Count	2 _T – < 1* CFU/mL 3 _T – <1* CFU/mL 4 _T – 2* CF/mL 5 _T – < 1* CFU/mL 6 _T – < 1* CFU/mL 8 _T – 26*CFU/mL 9 _T – < 1* CFU/mL 12 _T – 2* CFU/mL 14 _T – < 1* CFU/mL Lubas _T – < 1*CFU/mL JICA _{T1} – < 1* CFU/ml JICA _{T2} – 52 CFU/mL PPSS _{T1} – 5* CFU/mL SWAMP _T – < 1* CFU/mL A _T – < 1* CFU/mL PICOWELL _{T1} – < 1* CFU/mL PICOWELL _{T2} – < 1* CFU/mL	< 500 CFU/mL



REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0433
Date Submitted : May 9, 2018
Date Analyzed : May 9-11, 2018
Date Reported : May 15, 2018
Submitted by : Customer Name :
Name of Company : **LA TRINIDAD WATER DISTRICT**
Address : Km. 4, Balili, La Trinidad, Benguet

Page : Page 2 of 2

METHODOLOGY:

Total Coliform Count / *Escherichia coli*

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215B; 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from all terminal points NEGATIVE for *E. coli*. Heterotrophic Plate Count of all water samples are within the standard limit set by the PNSDW.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

*Estimated Heterotrophic Plate Count

Analyzed by:

Certified by:

Confirmed and Approved for Release by:


CLARISA ANGELLI L. NAGPALA
Analyst


JAMIE BETH B. GALIAN
Approved PAB Signatory


NANCY A. BANTOG
Quality Manager

Note: Not valid without DOST-CAR seal



DENR RECOGNIZED
C.R No. 078/2015

FDA ACCREDITED
FDA LA-2014-018


DOH ACCREDITED
14-001-17-LW-1

REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0432 and MIC-0434
Date Submitted : May 09, 2018
Date Analyzed : May 09-11, 2018
Date Reported : May 15, 2018
Submitted by : Customer Name :
Name of Company : **LA TRINIDAD WATER DISTRICT**
Address : Km. 4, La Trinidad, Benguet

Page : Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2007)
MIC-0853 to 0869 and MIC-0889 to MIC-0896	17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2 _s , 3 _s , 4 _s , 5 _s , 6 _s , 8 _s , 9 _s , 12 _s , 14 _s , Lubas _s , As _s , PPSS _s , JICA _{s1} , JICA _{s2} , SWAMP _s , Pico _s and Pico _{s2} .	Total Coliform Count	2 _s – >8 MPN/100 mL 3 _s – <1.1 MPN/100 mL 4 _s – >8 MPN/100 mL 5 _s – <1.1 MPN/100 mL 6 _s – <1.1 MPN/100 mL 8 _s – <1.1 MPN/100 mL 9 _s – <1.1 MPN/100 mL 12 _s – <1.1 MPN/100mL 14 _s – >8 MPN/100mL Lubas _s – >8 MPN/100mL As – >8 MPN/100 mL PPSS _s – >8 MPN/100mL JICA _{s1} – >8 MPN/100mL JICA _{s2} – <1.1 MPN/100mL Swamp _s – <1.1 MPN/100mL Pico _{s1} – >8 MPN/100mL Pico _{s2} – <1.1 MPN/100mL	<1.1 MPN/100mL
		<i>E. coli</i>	2 _s – >8 MPN/100 mL 4 _s – >8 MPN/100 mL 14 _s – >8 MPN/100mL Lubas _s – >8 MPN/100MI As – >8 MPN/100 mL PPSS _s – >8 MPN/100mL JICA _{s1} – >8 MPN/100mL Pico _{s1} – >8 MPN/100mL	<1.1 MPN/100mL



DENR RECOGNIZED
C.R No. 078/2015

FDA ACCREDITED
FDA LA-2014-018

DOH ACCREDITED
14-001-17-LW-1

REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0432 and MIC-0434
Date Submitted : May 09, 2018
Date Analyzed : May 09-11, 2018
Date Reported : May 15, 2018
Submitted by : Customer Name :
Name of Company : **LA TRINIDAD WATER DISTRICT**
Address : Km. 4, La Trinidad, Benguet
Page : Page 2 of 2

		Heterotrophic Plate Count	2 _s - 465 CFU/mL 3 _s - < 1* CFU/mL 4 _s - 58 CFU/mL 5 _s - 6* CFU/mL 6 _s - 42 CFU/mL 8 _s - 79 CFU/mL 9 _s - 170 CFU/mL 12 _s - < 1* CFU/mL 14 _s - 242 CFU/mL Lubass- 194 CFU/mL A _s - 265 CFU/mL PPSS _s - 510 CFU/mL JICA _{s1} - 245 CFU/mL JICA _{s2} - < 1* CFU/mL Swamp _s - < 1* CFU/mL Pico _{s1} - 42 CFU/100mL Pico _{s2} - 47 CFU/100mL	<500 CFU/mL
--	--	----------------------------------	---	-------------

METHODOLOGY:

Total Coliform Count / *Escherichia coli*

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2_s, 4_s, 14_s, Lubass_s, A_s, PPSS_s, JICA_{s1} and Pico_{s1} are POSITIVE for *E. coli*.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

* Estimated Heterotrophic Plate Count

Analyzed by:

Confirmed and Approved for Release by:


JAMIE BETH B. GALIAN
Approved PAB Signatory


NANCY A. BANTOG
Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601
Tel. No. (63)(074)422-0979
Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com
URL: <http://car.dost.gov.ph>



DENR RECOGNIZED
C.R No. 078/2015

FDA ACCREDITED
FDA LA-2014-018

DOH ACCREDITED
14-001-17-LW-1

REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0432 and MIC-0434
Date Submitted : May 09, 2018
Date Analyzed : May 09-11, 2018
Date Reported : May 15, 2018
Submitted by : Customer Name :
Name of Company : **LA TRINIDAD WATER DISTRICT**
Address : Km. 4, La Trinidad, Benguet

Page : Page 1 of 2

SAMPLE CODE	SAMPLE DESCRIPTION	TEST	RESULT	STANDARD (PNS for Drinking Water, 2007)
MIC-0853 to 0869 and MIC-0889 to MIC-0896	17 Domestic water samples from source points placed in sterilized reagent bottles and with written labels, 2 _s , 3 _s , 4 _s , 5 _s , 6 _s , 8 _s , 9 _s , 12 _s , 14 _s , Lubas _s , As _s , PPSS _s , JICA _{s1} , JICA _{s2} , SWAMP _s Pico _s and Pico _{s2} .	Total Coliform Count	2 _s - >8 MPN/100 mL 3 _s - <1.1 MPN/100 mL 4 _s - >8 MPN/100 mL 5 _s - <1.1 MPN/100 mL 6 _s - <1.1 MPN/100 mL 8 _s - <1.1 MPN/100 mL 9 _s - <1.1 MPN/100 mL 12 _s - <1.1 MPN/100mL 14 _s - >8 MPN/100mL Lubas _s - >8 MPN/100mL As _s - >8 MPN/100 mL PPSS _s - >8 MPN/100mL JICA _{s1} - >8 MPN/100mL JICA _{s2} - <1.1 MPN/100mL Swamps _s - <1.1 MPN/100mL Pico _{s1} - >8 MPN/100mL Pico _{s2} - <1.1 MPN/100mL	<1.1 MPN/100mL
		<i>E. coli</i>	2 _s - >8 MPN/100 mL 4 _s - >8 MPN/100 mL 14 _s - >8 MPN/100mL Lubas _s - >8 MPN/100MI As _s - >8 MPN/100 mL PPSS _s - >8 MPN/100mL JICA _{s1} - >8 MPN/100mL Pico _{s1} - >8 MPN/100mL	<1.1 MPN/100mL



DENR RECOGNIZED
C.R No. 078/2015

FDA ACCREDITED
FDA LA-2014-018

DOH ACCREDITED
14-001-17-LW-1

REPORT OF ANALYSIS

Req. Ref. No. : CAR-052018-MIC-0432 and MIC-0434
Date Submitted : May 09, 2018
Date Analyzed : May 09-11, 2018
Date Reported : May 15, 2018
Submitted by : Customer Name :
Name of Company : **LA TRINIDAD WATER DISTRICT**
Address : Km. 4, La Trinidad, Benguet
Page : Page 2 of 2

		Heterotrophic Plate Count	2 _s - 465 CFU/mL 3 _s - < 1* CFU/mL 4 _s - 58 CFU/mL 5 _s - 6* CFU/mL 6 _s - 42 CFU/mL 8 _s - 79 CFU/mL 9 _s - 170 CFU/mL 12 _s - < 1* CFU/mL 14 _s - 242 CFU/mL Lubass- 194 CFU/mL As - 265 CFU/mL PPSS _s - 510 CFU/mL JICA _{s1} - 245 CFU/mL JICA _{s2} - < 1* CFU/mL Swamp _s - < 1* CFU/mL Pico _{s1} - 42 CFU/100mL Pico _{s2} - 47 CFU/100mL	<500 CFU/mL
--	--	----------------------------------	---	-------------

METHODOLOGY:

Total Coliform Count / *Escherichia coli*

Multiple Tube Fermentation Technique-Most Probable Number (MPN). Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9221A, B and C; 9223A and B (Modified) and in accordance with Merck Microbiological Manual, 12th Edition.

Heterotrophic Plate Count

Pour Plate - Colony Forming Units (CFU) per ml. Following Standard Methods for the Examination of Water and Waste Water, 22nd Edition 2012, Microbiological Examination 9000: 9215A and B.

REMARKS: Domestic water samples from 2_s, 4_s, 14_s, Lubass, As, PPSS_s, JICA_{s1} and Pico_{s1} are POSITIVE for *E. coli*.

The results given in this report are those obtained at the time of test and refer only to the particular sample submitted. This report shall not be reproduced except in full, without the written approval of the laboratory.

* Estimated Heterotrophic Plate Count

Analyzed by:


JAMIE BETH B. GALIAN
Approved PAB Signatory

Confirmed and Approved for Release by:


NANCY A. BANTOG
Quality Manager

Note: Not valid without DOST-CAR seal

Address: BSU Compound, Km.6, La Trinidad, Benguet 2601
Tel. No. (63)(074)422-0979
Fax No. (63)(074)422-2214

e-mail address: rstlcar@gmail.com
URL: <http://car.dost.gov.ph>