




Republic of the Philippines
LA TRINIDAD WATER DISTRICT
FA 249-B Km. 4, Balili, La Trinidad
Benguet Province 2601
Tel. Nos.: (074) 422-2679 / (074) 422-2078
Telefax No.: (074) 422-1848

REQUEST FOR QUOTATION

Date : May 5, 2022
Quotation No. : 0413-05-2022

Company Name :
Address :

Please quote your lowest price on the item/s listed below, subject to the General Conditions stating the shortest time of delivery and submit your quotation duly signed by you or your representative on or before 3:00 PM of May 12, 2022 in a sealed envelope.


SHEENA B. GREGORIO
Customer Service Assistant B.

General Conditions:

- Bidders must secure a copy of the original Request for Quotation at the La Trinidad Water District Office from the BAC Secretariat during office hours and to be submitted through postal/ courier services or personally delivered to Mrs. Sheena B. Gregorio Customer Service Assistant B, La Trinidad Water District, F.A.249-B, Balili, La Trinidad, Benguet
- Only Original Copies of Request for Quotation will be evaluated
- All entries must be printed/typed written.
- Delivery period within **Ten (10)** Calendar Days upon receipt of the Purchase Order.
- Warranty shall be for a period of six (6) months for supplies and materials and one (1) year for equipment from date of acceptance by the procuring entity,
- Prices quoted shall be inclusive of taxes, FOB La Trinidad and in Philippine Pesos
- Price validity shall be for a period of Thirty (30) Calendar Days.
- The following shall be attached upon submission of the Request for Quotation:
 - PhilGEPS registration
 - Valid Mayor's Permit
 - Statement that it is not blacklisted or barred from bidding by the Gov't or any of its agency, office, corporation or LGU.
 - Sworn statement that it is not related to the Head of Procuring Entity by consanguinity or affinity up to the third civil degree.
 - Original brochures showing specifications of the products being offered.
- For Lot Award

All items to be grouped together to form one (1) complete Lot that will be awarded to one Bidder to form one (1) complete contract. Bidder must offer/quote on all items, otherwise, bidder shall be automatically be disqualified.
- Award of contract shall be made to the lowest quotation which complies with the minimum technical specifications and other terms and conditions stated therein.
- Any interlineations, erasures or overwriting shall be valid only if they are signed or initialed by the bidder or his/her duly authorized representative/s.
- Liquidated damages equivalent to one tenth of one percent (0.001 %) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day of delay. The LTWD shall rescind the contract once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract without prejudice to other courses of action and remedies open to it.
- The LTWD reserves the right to accept or reject any or all quotations and to impose additional terms and conditions as it may deem proper.
- Bidders must state either "Comply" or "Not Comply" against each of the individual parameters of each specification stating the corresponding performance of the equipment/ materials/ fittings being offered.

Item No.	Item and Description	Statement of Compliance	Quantity	Unit	Unit Price	Lot Price
a	Generator Set 50 KVA, 220 V, 3 Phase		(One) 1	unit		
	60Hz					
	see ANNEX A for the full specifications.					
	NOTE:					
	1. Approved Budget for the Contract: PhP 1,300,000.00					



PR No.: 0413-05-2022

ANNEX A

TECHNICAL SPECIFICATIONS FOR 50 KVA , 220V, 3 PHASE, 60 Hz GENERATOR SET

1. Electrical Data

Rated Frequency	: 60 Hz
Rated Voltage	: 220 VAC three (3) phase
Prime Power (PRP)	: 50 KVA
Rated Standby Power	: 55 KVA
Power Factor	: 0.8
Rated Current	: 144.3 Amperes
Single Step Load Capacity	: 100%
Operating Temperature	: 50 C

2. Fuel Consumption

Full Tank Capacity	: ≥ 150 liters
Fuel Consumption at 50%	: ≤ 6.0 kg/h (7.2 l/h)
Fuel Consumption at 75%	: ≤ 8.4 kg/h (10 l/h)
Fuel Consumption at 100%	: ≤ 11.0 kg/h (13.22 l/h)
Fuel Consumption at 110%	: ≤ 12.2 kg/h (14.66 l/h)
Fuel Autonomy at Full Load	: ≤ 11.6 h

3. Engine

Speed	: 1800 rpm
Rated Net Power	: 53.9 Kw
Aspiration	: Turbocharged
Speed Control	: Mechanical
Number of Cylinder	: 3
Coolant	: Parcool
Swept Volume	: 3.3 L
Fuel	: Diesel

4. Alternator

Rated Output	: 58 KVA
Degree of Protection	: IP23/H

5. Noise Level

Sound Power Level	: ≤ 98 Db(A)
Sound Pressure Level at 7m	: ≤ 72 Db(A)

6. Dimensions and Weight

Length	: ≤ 2100 m m
Width	: ≤ 950 mm
Height	: ≤ 1326 mm
Weight (dry/wet)	: $\leq 1185 / 1354$ kg

With the following features:

- Full monitoring system
- 4 pole breaker
- Emergency Stop
- Earth leakage protection
- Battery Charger
- Coolant Heater
- 1-side serviceability (control panel side) through big access doors and panels
- Access to alternator (AVR and diode bridge)
- Full access to engine
- Direct radiator cleaning access
- External drain points access